



Notes:

1. Applies to services, watermain, and sanitary sewer.
2. Pipe shall be centered under insulation unless otherwise specified.
3. Also applies when pipe crosses within 2.5' of storm sewer, with the (a) being the separation distance between the pipes.

Cover over pipe (a)	Width of insulation board (b)	Thickness of insulation board (c)
2'-3'	11'	6"
3'-4'	9'	5"
4'-8'	7'	4"

M:\STANDARD SPECS & DETAILS\2019\Detail Plates\BED-5 INSULATION.dwg

City Plate No.:
BED-5
Last Revision:
6/5/2019
File:
BED-5.dwg

**STANDARD DETAILS
INSULATION**

