


Precast invert shall be 1/2 diameter of pipe and benches shall be sloped 2" toward invert.

Casting	Lid Type	A	B
1642	B	27"	7"

PLAN



Neenah frame and Type B cover or equal, lettered "Sanitary Sewer" with 2 concealed pick holes Type F.

Adjustment rings per STR-1 standard detail.

Notes:

1. Precast concrete sections only. No block structures allowed.
2. Rubber gaskets or premium butyl rubber joint sealant on all riser section joints.
3. Precast monolithic base with precast invert required.
4. Orient cone section so opening is over outlet pipe.
5. Line interior in the field per specifications.

Watertight, booted pipe connection, ASTM C923, cast into the structure. Pipe shall be cut out flush with inside face of wall.

Minimum thickness of precast base is 6" for 14' deep or less, and increases 1" in thickness for every 4' of depth greater than 14'.

* Determined by pipe size.

SECTION

12" NDDOT Class 3M aggregate base

M:\STANDARD SPECS & DETAILS\2019\Detail Plates\SAN-2_SANITARY SEWER JUNCTION MANHOLE.dwg

City Plate No.:
SAN-2
Last Revision:
6/17/2019
File:
SAN_2.dwg

**STANDARD DETAILS
SANITARY SEWER
JUNCTION MANHOLE**

