



Notes:

1. Pumper connection shall face the street.
2. Hydrant shall be 9'-0" bury.
3. 8 mil poly around hydrant barrel.
4. Gate valve box per separate standard detail.

M:\STANDARD SPECS & DETAILS\2019\Detail Plates\WAT-2_HYDRANT DETAIL WITH VERTICAL BEND.dwg

City Plate No.:
WAT-2

Last Revision:
6/5/2019

File:
WAT_2.dwg

**STANDARD DETAILS
HYDRANT
WITH VERTICAL BEND**

