



**Notes:**

1. Pumper connection shall face the street.
2. Hydrant shall be 9'-0" bury.
3. 8 mil poly around hydrant barrel.
4. Gate valve box per separate standard detail.

C:\Users\stakeard\Desktop\MINOT DETAIL\SSTR-8 PEDESTRIAN CURB RAMP PATHWAY-SIDEWALK.dwg

City Plate No.: WAT-2
Last Revision: 4/11/2019
File: WAT_2.dwg

**STANDARD DETAILS  
HYDRANT DETAIL  
WITH VERTICAL BEND**

