



TYPICAL INSTALLATIONS

RESTRAINED LENGTHS OF PVC PIPE						
NOM. PIPE SIZE	90° BEND (L)	45° BEND (L)	22.5° BEND (L)	11.25° BEND (L)	SIZE ON SIZE TEE (L)*	VALVE DEAD-END (L)
6"	19'	8'	4'	2'	2'	35'
8"	25'	11'	5'	3'	13'	45'
10"	31'	13'	6'	3'	23'	55'
12"	36'	15'	8'	4'	33'	65'
16"	47'	20'	10'	5'	52'	84'

* Recommended restrained lengths for tees are for the branch outlet and assume a minimum 10' section of pipe attached to each side of the run. Restraint devices are also required on both run joints of the tee itself.

SIZE	45° VERT. OFFSET * (L)	22.5° VERT. OFFSET * (L)
6"	15'8"	7'4"
8"	19'11"	9'5"
10"	23'13"	11'6"
12"	27'15"	13'8"
16"	35'20"	17'10"

* First number is the recommended restrained length on each side of the down bend. The second number is the length for each side of the up bend.

C:\Users\skennard\Desktop\MINOT\DETAIL\SICATCH\BASIN.dwg

City Plate No.:
WAT-10
Last Revision:
4/11/2019
File:
WAT_10.dwg

STANDARD DETAILS RESTRAINT DEVICE FOR PVC PIPE BELL JOINTS

