



Notes:

1. Applies to services, watermain, and sanitary sewer.
2. Pipe shall be centered under insulation unless otherwise specified.
3. When pipe crosses within 2.5' of storm sewer, see detail BED-6.
4. When stacking insulation boards, stagger each layer such that all butt joints are overlapped by the layer above (18" min.)

Cover over pipe (a)	Width of insulation board (b)	Thickness of insulation board (c)
> 4'	*	*
4'-6'	6'	6"
6'-8'	4'	4"

*Services, watermains, and sanitary sewers with less than 4' of cover need prior approval from Public Works Department prior to installation.

STANDARD SPECS & DETAIL S/2021/Detail/BED-5 INSULATION.dwg

City Plate No.:
BED-5
Last Revision:
12/18/2020
Section:
2100, 2200, 2300, 2400

**STANDARD DETAILS
INSULATION**

