



- Notes:**
1. Insulation required where service is less than 8.5' deep per detail BED-5.
  2. Use connection option "A" if ex. wye bell is good, "B" when ex. wye bell is broken & "C" when ex. wye is broken down to the main.
  3. Pipes shall be butted together with repair coupling centered on butt-joint.

M:\STANDARD SPECS & DETAIL S\2021\10\16\11\SER-4 - SEWER SERVICE FOR REPLACEMENT PROJECTS.dwg

City Plate No.: SER-4
Last Revision: 12/18/2020
Section: 2400

**STANDARD DETAILS  
SEWER SERVICE FOR  
REPLACEMENT PROJECTS**

